



Town of Lunenburg

Process Equipment Pre-Selection

CONTRACT NO. 240800.00Q

ADDENDUM NO. 1

April 25, 2024

(To be added to and made part of the Tender Documents)

The following changes or modifications shall be made to the Tender Documents:

TO THE SPECIFICATIONS

SECTION 00 21 14 INFORMATION TO PROPONENTS

Page 2, delete subsection 3.2 and replace as follows:

- 3.2 Quotation must be forwarded to the Consultant no later than **3:00p.m., local time on Friday May 10, 2024**, hereinafter referred to as the Closing Date.

Page 6, delete subsection 8.1 and replace as follows:

- 8.1 Within five (5) weeks of the Owner placing a purchase order for the equipment shop drawings, the Supplier shall submit to the Consultant for approval, detailed shop drawings and product information for the equipment to be supplied as noted in the technical specifications.

Page 9, delete subsection 8.1 and replace as follows:

- 12.3 The Supplier shall quote a guaranteed equipment delivery period once both of the following have been received:
- .1 Approved submittals from Consultant and Owner.
 - .2 Acceptance of a PO between the General Contractor and the Supplier.



SECTION 00 41 01 FORM OF QUOTATION

Page 7, delete subsection 5.3 and replace as follows:

- 5.3 Equipment payment will be permitted at the following milestones during the execution of the General Contract:
- .1 20% due upon release of equipment for fabrication.
 - .2 60% due upon delivery of equipment to the construction site.
 - .3 10% due upon installation of equipment into the works of the treatment plant.
 - .4 10% due upon successful completion of trial testing, Commissioning, and operator training.

SECTION 43 32 63 ULTRAVIOLET DISINFECTION SYSTEMS

Page 1, delete subsection 1.3.1.7 and replace as follows:

- .7 The UV system is to be installed in an existing concrete channel of following dimensions: 610 mm x 914 mm x 7,925 mm / 2.00' x 3.00' x 26.00' (w x d x l). For further dimensions and elevations refer to annexed Drawing S1.

SECTION 44 41 13 – FINE SCREENING EQUIPMENT

Page 4, delete subsection 2.2.5.11 and replace as follows:

- .11 Carriage: type 316 stainless steel, spring loaded and adjustable, if applicable.

Page 9, add new subsection 2.7.1.2 as follows:

- .2 High level float switch to operate the screen during high flow events and provided alarm.

Page 16, delete subsection 3.3.5 and replace as follows:

- .5 A minimum period of ten (10) days on Site for skilled supervision and instruction and a minimum of three (3) trips to the Site should be assumed by the equipment manufacturer. This time may include all the tasks listed in the following subsection 3.4. Provide as many trips and days on Site to complete the installation and put equipment into satisfactory operation.



SECTION 46 53 53 – SBR PROCESS EQUIPMENT

Page 4, delete subsection 2.1.6.6 and replace as follows:

- .6 Existing diffuser airflow capacity: 1660 scfm. Sludge Holding Tank blowers do not have to match this airflow if a lower capacity is sufficient for mixing and oxygen needs.

CBCL Limited
April 25, 2024