

TOWN OF LUNENBURG

TOLRFQ005

Lift Pump Station Pumps & Generators 2025-26

ADDENDUM #1

1. Are the inspections to be completed onsite or can they be removed and sent to our shop in Saint John. The reason for asking is that without removing and dis-assembling the unit, an inspection report will not reveal any internal issues which is the norm.

A: Pumps are needed to remain in operation of the system so shall need to be assessed onsite.

2. Do you have a checklist of inspection data required by the Town – perhaps a template from past inspections.

A: Inspection data is to be determined by the Proponent but should include all working components such as components of the pumps, gauges, instrumentation shall need to be inspected to ensure they are functional and of satisfactory condition. Readings, tolerances, electrical feeds should form a part of this.

3. Is there a list of pump make and models

A: Please see Addendum #2 – TOL Lift Station Pump Information

4. The tender refers to inspection quotes as detailed below but nothing is attached.

A: There may have been a misinterpretation of the request, it is intended that Proponents provide quotations for inspection in the space below.