

**TOWN OF LUNENBURG**

**RFP TOL2025005**

**ADDENDUM #1 – Water Meter Supply & Install**

1. Would the Town of Lunenburg consider an option to separate the tender into both supply & install to allow local plumbing companies to also be considered when bidding for the RFP.
  1. The RFP is to remain as a supply and install scope at this time.
  
2. Is this RFP completely new meter installs, meter replacements, or a combination of both? Would the requirement be licensed plumbers, certified installers or again, both?
  2. The Residential Customer portion of the scope would be mainly new meters, the Commercial Customer portion of the scope would mainly be replacement meters.
  
3. Would the town allow an alternative option to positive displacement meters? This would allow for newer metering technology to be considered which would benefit the town more. (i.e. magnetic flow, no moving parts meters). Such as the Sensus iPERL.
  3. If a Proponent has an alternative technology they wish to propose, they should do so in the Details of Proposal section (Page 17 of the RFP document) for the Town to review, along with all relevant supporting information and include it in their submission.
  
4. Can there be some clarification on why there is the need for two check valves per meter?
  4. The intent with the two check valves is to be able to isolate the meter for future maintenance, replacement, etc.