

TOWN OF LUNENBURG
TOL2025016

ADDENDUM #1 – Old Fire Hall Roof Membrane Replacement

5. Are both roof facets being completed (upper and lower) or is it exclusive to just 1? If so, which?

It is the Old Fire Hall Building Only (the upper roof). The lower roof is considered a different building.

6. Is the requested system tapered or just a membrane replacement? If it is tapered, what is the minimum thickness of insulation required and the degree of taper?

Just a membrane replacement.